

CONTENTS

1	Scope	1
2	Normative references	1
3	Terms and definitions	1
4	Method of measurement	1
4.1	Measurement principle	1
4.2	Measuring circuit	3
4.3	Requirements to the measuring system	4
4.3.1	Measuring frequency	4
4.3.2	Noise level of the measuring system	4
4.3.3	Third harmonic ratio of the measuring system	4
4.3.4	Power amplifier	4
4.3.5	Voltmeter	5
4.3.6	Filter	5
4.3.7	Test fixture	5
4.4	Verification of the measuring system	5
5	Measurement procedure	5
5.1	Environmental conditions	5
5.2	Preparation of specimen	5
5.3	Measurement conditions	5
5.4	Procedure	6
5.5	Precautions	6
6	Evaluation of measurement results	6
6.1	Evaluation	6
6.2	Requirements	7
7	Information to be given in the relevant component specification	7
	Table 1 — Recommended measuring conditions	8
	Annex X (informative) Cross reference	10
	BIBLIOGRAPHY	11

METHOD OF MEASUREMENT OF NON-LINEARITY IN RESISTORS

1 Scope

Non-linearity testing is a method for evaluation of the integrity of a resistive element. It may be applied as an effective inline screening method suitable to detect and eliminate potential infant mortality failures in passive components. The method is fairly rapid, convenient, and the associated equipment is relatively inexpensive.

Typical effects causing non-linearity on resistors are e.g. inhomogeneous spots within a resistive film, traces of film left in the spiraling grooves, or contact instability between connecting lead or termination and the resistive element.

This international standard specifies a method of measurement and associated test conditions for determining the magnitude of non-linear distortion generated in a resistor. This method shall be applied if prescribed by a relevant component specification, or if agreed between a customer and a manufacturer.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendment) applies.

IEC 60068-1, *Environmental testing - Part 1: General and guidance*

3 Terms and definitions

Non-linearity

deviation of a component's impedance from Ohm's law, resulting in voltage of harmonic frequencies when subjected to sinusoidal current

Third harmonic ratio

A_3

ratio of the fundamental voltage over the e.m.f. of the third harmonic, expressed in dB

NOTE The third harmonic ratio has been addressed before as third harmonic attenuation. This historic convention is misleading as it wrongly suggests harmonic frequencies originating from the test equipment being attenuated or filtered by the components under test. The misleading term should therefore be avoided.

4 Method of measurement


4.1 Measurement principle

A pure sinusoidal current is passed through the component under test. If the impedance of the component is not perfectly linear, the voltage across the component will be distorted and contain harmonics. One or more of these harmonics can be measured and the magnitude of these distortions is a measure of the non-linearity in the component. It is recommended to measure the third harmonic, as this is the dominant one.

The third harmonic voltage appearing across a component must be separated from the fundamental voltage and from any other harmonic voltage for the measurement. This is accomplished by a filter circuit letting the harmonic voltage pass through while featuring very high impedance at the fundamental frequency. Likewise, the generator of the fundamental frequency needs to feature very

41 high impedance at the third harmonic frequency in order not to act as a load to the generated
42 distortions.

43 Hence the equivalent circuit of the generator part operating at the fundamental frequency is quite
44 simple as shown in Figure 1.



Key:


I_1 Sinusoidal current

U_1 Fundamental voltage across the resistor under test

R_T Impedance of the resistor under test at the fundamental frequency

Figure 1 — Equivalent circuit at the fundamental frequency.

45 The equivalent circuit for the third harmonic frequency is built around the test specimen represented
46 by a linear impedance with a zero-impedance harmonic generator in series. This signal source loads
47 the measuring system represented by its impedance as seen from the test terminals, see Figure 2.



Key:

E_3 e.m.f. of the third harmonic

R_{T3} Impedance of the resistor under test at the third harmonic frequency

R_3 Impedance of the measuring circuit at the third harmonic frequency,
seen from the test terminals

U_3 Third harmonic voltage

Figure 2 — Equivalent circuit at the third harmonic frequency.

48 In this circuit the e.m.f. of the third harmonic E_3 is divided to the measurable third harmonic voltage U_3

49
$$U_3 = \frac{R_3}{R_3 + R_{T3}} \cdot E_3 \quad (1)$$

50 Hence the e.m.f. of the third harmonic E_3 in the component can be determined by

51
$$E_3 = \left(1 + \frac{R_{T3}}{R_3}\right) \cdot U_3 \quad (2)$$

52 The corrective term Δ for the reduction of U_3 to the origin E_3 is

53
$$\Delta = 20 \cdot \log_{10} \left(1 + \frac{R_{T3}}{R_3}\right) \quad (3)$$

In many cases it can be shown for a range of resistors under test that the impedance R_{T3} at the third harmonic frequency is equal or very close to the impedance R_T at the fundamental frequency. Then the corrective term Δ in decibels is

$$\Delta = 20 \cdot \log_{10} \left(1 + \frac{R_T}{R_3} \right)$$

(4)

NOTE For fixed film resistors this equality of R_{T3} and R_T can generally be assumed with sufficient accuracy.

Numeric values for the corrective term Δ can be obtained from Figure 3 or for specific sets of impedance R_3 and specimen resistance R_T from Table 1.




Figure 3 — Correction Term Δ

A suitable range for the fundamental frequency f_1 for measurements on resistors is between 10 kHz and 40 kHz. This frequency range enables the test circuit to be set up without too much difficulty.

NOTE Another method is using a bridge which is balanced at the fundamental frequency, where the harmonics appear across the bridge diagonal. This method requires individual balancing of the bridge for each specimen, which may be suitable for occasional use in a laboratory environment.


4.2 Measuring circuit

Figure 4 shows a block schematic of a suitable measuring circuit.

A distortion-free impedance matching device may be used to switch R_3 in order to achieve good matching to the test specimen R_T . Examples of suitable values of R_3 are 10 Ω ; 100 Ω ; 1 000 Ω ; 10 000 Ω and 100 000 Ω , which values are used for specifying the test conditions in Table 1.

The suitability of the measuring circuit for measurements on resistors with resistance values covering a wide range depends on the lowest and highest available impedance R_3 of the circuit. The range of values for R_3 proposed above grants suitability for measurements on resistors with resistance values between 1 Ω and at least 10 M Ω .

75 However, there is an overriding influence of the correcting term Δ depending on the ratio of resistance
 76 under test R_T over impedance R_3 , see Table 1 and Figure 3.



Key:

- G Oscillator, at the fundamental frequency f_1
- S Switch for applying the test signal to the test specimen
- VA Variable attenuator
- A Power amplifier
- LP Low-pass filter
- U_1 R.M.S. voltage at the fundamental frequency f_1
- BP Band-pass filter
- U_3 R.M.S. voltage at the third harmonic frequency f_3
- R_T Resistor under test
- R_3 Impedance of the measuring circuit at the third harmonic frequency f_3 , seen from the test terminals.

Figure 4 — Block schematic of a suitable measuring system

77 4.3 Requirements to the measuring system

78 4.3.1 Measuring frequency

79 The fundamental frequency f_1 shall be 10 kHz and thus the third harmonic frequency f_3 shall be
 80 30 kHz, unless otherwise specified in the relevant component specification.

81 4.3.2 Noise level of the measuring system

82 The noise level referred to the test terminals shall not be higher than 0,2 μ V at $R_3 = 1\,000\,\Omega$.

83 4.3.3 Third harmonic ratio of the measuring system

84 The third harmonic ratio $20 \cdot \log_{10}(U_1/E_3)$ shall be higher than 140 dB for most of the impedance
 85 range when the required dissipation P is applied to a virtually linear component.

86 The required dissipation is 0,25 VA, as given in Table 1, or a value prescribed by the relevant
 87 component specification, e.g with reference to the rated dissipation.

88 4.3.4 Power amplifier

89 The power amplifier shall be capable of delivering an apparent power of four times the required
 90 dissipation into a resistive component under test, in order to ensure sufficient linearity.

91 Hence the power amplifier shall be capable of delivering an apparent power of 1 VA if the required
 92 dissipation is 0,25 VA as given in Table 1.

93 4.3.5 Voltmeter

94 The error of the voltmeter for measurement of the voltage U_1 at the fundamental frequency voltmeter
95 shall be less than 5 % of its full scale deflection.

96 The error of the voltmeter for measurement of the voltage U_3 at the third harmonic frequency shall be
97 less than 10 % of its full scale deflection.

98 4.3.6 Filter

99 The cut-off frequency of the low-pass filter shall be immediately above the fundamental frequency f_1 .

100 The band-pass filter shall permit the third-harmonic frequency f_3 to pass through, while it shall provide
101 very high attenuation at the fundamental frequency f_1 .

102 Precautions shall be taken to avoid non-linear distortion from the components near the test specimen
103 in the low-pass and band-pass filters. The filter inductors for instance shall not contain cores of
104 magnetic material.

105 4.3.7 Test fixture

106 The test fixture for the specimen R_T shall be capable of providing safe electrical connection.

107 4.4 Verification of the measuring system

108 Reference resistors with known non-linearity shall be used to verify the integrity of the measuring
109 system.

110 5 Measurement procedure

111 5.1 Environmental conditions

112 Unless otherwise specified, all tests shall be carried out under standard atmospheric conditions for
113 measurement and tests as specified in IEC 60068-1.

114 5.2 Preparation of specimen

115 The specimen shall be kept for at least 2 h in the environmental conditions prescribed in 5.1.

116 5.3 Measurement conditions

117 The choice of system impedances R_3 is determined by the properties of the actual measurement
118 system. Table 1 is based on examples of suitable values for R_3 .

119 The fundamental test voltage U_1 shall be chosen from Table 1, unless otherwise specified in the
120 relevant component specification, e.g. relative to the rated dissipation.

121 NOTE Analysis shows that the third harmonic ratio depends significantly on the choice of the fundamental
122 voltage as the readings of the third harmonic voltage U_3 show an exponential relationship over the
123 ratio of applied fundamental voltages. Comparison of the non-linearity of different products therefore
124 should always be based on identical prescriptions for dissipation and voltage limitation in order to
125 define an identical fundamental voltage for each resistance value.

126 The application of the fundamental voltage results in a dissipation and thus in a temperature rise within
127 the specimen. Depending on its temperature coefficient of resistance (TCR), the specimen resistance
128 will change, which will change the actual applied fundamental voltage. Depending on the respective
129 temperature rise and TCR, this effect may be neglectable or not. Limiting the duration of the

130 application of the fundamental voltage may be a suitable way out of this problem, if set below the
131 thermal time constant of the specimen.

132 The relevant component specification shall state respective requirements, if applicable.

133 5.4 Procedure

134 The specimen shall be inserted into the test fixture and properly connected to the test terminals.

135 The system impedance R_3 shall be selected in order to achieve the best possible impedance
136 matching.

137 The fundamental voltage shall be applied, e.g. by closing the switch S in a system according to Figure
138 4, and adjusted to the prescribed value.

139 The third harmonic voltage U_3 shall be read.

140 The application of the fundamental voltage shall not exceed the prescribed duration, if applicable.

141 5.5 Precautions

142 Ferromagnetic materials give rise to harmonic distortion and care must be taken to avoid influence
143 from, e.g. iron in the immediate vicinity of the component which can mask component non-linearities
144 especially at high currents.

145 6 Evaluation of measurement results

146 6.1 Evaluation

147 The reading of the third harmonic voltage U_3 shall be used to calculate the third harmonic ratio.

148 The third harmonic ratio A_3 in decibels is

$$\begin{aligned}
 A_3 &= 20 \cdot \log_{10} \frac{U_1}{E_3} \\
 &= 20 \cdot \log_{10} \frac{U_1}{U_{\text{ref}}} - 20 \cdot \log_{10} \frac{E_3}{U_{\text{ref}}} \\
 &= 20 \cdot \log_{10} \frac{U_1}{U_{\text{ref}}} - 20 \cdot \log_{10} \frac{U_3}{U_{\text{ref}}} - 20 \cdot \log_{10} \left(1 + \frac{R_{T3}}{R_3} \right)
 \end{aligned} \tag{5}$$

150 with
151 U_1 Fundamental voltage across the resistor under test
152 U_{ref} Basis for voltage ratios, arbitrarily set.
153 E_3 e.m.f. of the third harmonic in the component
154 U_3 measured third harmonic voltage
155 R_{T3} Impedance of the resistor under test at the third harmonic frequency
156 R_3 Impedance of the measuring circuit at the third harmonic frequency, seen from the test
157 terminals (source impedance)

158 In equation 5, the logarithmic term describing the fundamental voltage may be abbreviated as D with

$$D = 20 \cdot \log_{10} \frac{U_1}{U_{\text{ref}}} \tag{6}$$

160 NOTE The calculation of the third harmonic ratio requires a common U_{ref} for all used logarithms of voltage
161 ratios; throughout this document, $U_{\text{ref}} = 1 \text{ V}$ is used for the 0 dB reference level.

162 The abbreviation of a logarithmic expression $20 \cdot \log_{10}(U/U_{\text{ref}})$ to $20 \cdot \log_{10}U$ is mathematically incorrect
 163 and particularly bears the risk of confusion when the used reference voltage is no longer considered.
 164 Hence the abbreviated form should not be used.

165 With the above definitions of D in equation 6 and of Δ in 4.1, equation 5 can be simplified to

$$166 \quad A_3 = D - 20 \cdot \log_{10} \frac{U_3}{U_{\text{ref}}} - \Delta \quad (7)$$

167 6.2 Requirements

168 Acceptance criteria for non-linearity of tested products shall be given with reference to a required
 169 minimum third harmonic ratio A_3 in the relevant component specification.

170 Such acceptance criteria should be stated through a fixed minimum value, typically given as a function
 171 of the specimen resistance.

172 Superiour selectivity of non-linearity screening is achievable through the use of a dynamic minimum
 173 value relative to the statistical distribution of non-linearity within an analyzed batch in addition to a
 174 fixed minimum value. Such dynamic requirement should be referenced to a batch's mean value and a
 175 multiple of its standard deviation, e.g. like $\geq \bar{A}_3 - 3\sigma$.

176 7 Information to be given in the relevant component specification

177 When this test is included in a relevant component specification, the following details shall be given as
 178 far as they are applicable:

179		Clause
180	a) the fundamental frequency	4.2
181	b) the environmental condition for this measurement	5.1
182	c) the dissipation to be provided through the fundamental voltage	5.3, Table 1
183	d) a limitation to the fundamental voltage, if applicable	5.3, Table 1
184	e) a limitation to the duration of application of the fundamental voltage, if applicable	5.3

185 The relevant component specification shall specify for its own purpose:

186		Clause
187	f) acceptance criteria to the third harmonic ratio A_3	6.2

Table 1 — Recommended measuring conditions

R_3 Ω	R_T^a Ω	Δ^b dB	Specimen's rated dissipation P_r								
			$P_r \geq 0,25 \text{ W}$			$0,25 \text{ W} > P_r \geq 0,1 \text{ W}$			$0,1 \text{ W} > P_r$		
			U_1^c V	D^d dB	P mW	U_1^c V	D^d dB	P mW	U_1^c V	D^d dB	P mW
10	1,0	0,8	0,50	-6,0	250	0,32	-10,0	100	0,22	-13,0	50
	1,2	1,0	0,55	-5,2	250	0,35	-9,2	100	0,24	-12,2	50
	1,5	1,2	0,61	-4,3	250	0,39	-8,2	100	0,27	-11,2	50
	1,8	1,4	0,67	-3,5	250	0,42	-7,4	100	0,30	-10,5	50
	2,2	1,7	0,74	-2,6	250	0,47	-6,6	100	0,33	-9,6	50
	2,7	2,1	0,82	-1,7	250	0,52	-5,7	100	0,37	-8,7	50
	3,3	2,5	0,91	-0,8	250	0,57	-4,8	100	0,41	-7,8	50
	3,9	2,9	0,99	-0,1	250	0,62	-4,1	100	0,44	-7,1	50
	4,7	3,3	1,08	0,7	250	0,69	-3,3	100	0,48	-6,3	50
	5,6	3,9	1,18	1,5	250	0,75	-2,5	100	0,53	-5,5	50
	6,8	4,5	1,30	2,3	250	0,82	-1,7	100	0,58	-4,7	50
	8,2	5,2	1,43	3,1	250	0,91	-0,9	100	0,64	-3,9	50
	10	6,0	1,58	4,0	250	1,00	0,0	100	0,71	-3,0	50
	12	6,8	1,73	4,8	250	1,10	0,8	100	0,77	-2,2	50
	15	8,0	1,94	5,7	250	1,22	1,8	100	0,87	-1,2	50
	18	8,9	2,12	6,5	250	1,34	2,6	100	0,95	-0,5	50
	22	10,1	2,35	7,4	250	1,48	3,4	100	1,05	0,4	50
	27	11,4	2,60	8,3	250	1,64	4,3	100	1,16	1,3	50
100	33	2,5	2,87	9,2	250	1,82	5,2	100	1,28	2,2	50
	39	2,9	3,12	9,9	250	1,97	5,9	100	1,40	2,9	50
	47	3,3	3,43	10,7	250	2,17	6,7	100	1,53	3,7	50
	56	3,9	3,74	11,5	250	2,37	7,5	100	1,67	4,5	50
	68	4,5	4,12	12,3	250	2,61	8,3	100	1,84	5,3	50
	82	5,2	4,53	13,1	250	2,86	9,1	100	2,02	6,1	50
	100	6,0	5,00	14,0	250	3,16	10,0	100	2,24	7,0	50
	120	6,8	5,48	14,8	250	3,46	10,8	100	2,45	7,8	50
	150	8,0	6,12	15,7	250	3,87	11,8	100	2,74	8,8	50
	180	8,9	6,71	16,5	250	4,24	12,6	100	3,00	9,5	50
	220	10,1	7,42	17,4	250	4,69	13,4	100	3,32	10,4	50
	270	11,4	8,22	18,3	250	5,20	14,3	100	3,67	11,3	50
1 k	330	2,5	9,08	19,2	250	5,74	15,2	100	4,06	12,2	50
	390	2,9	9,87	19,9	250	6,24	15,9	100	4,42	12,9	50
	470	3,3	10,8	20,7	250	6,86	16,7	100	4,85	13,7	50
	560	3,9	11,8	21,5	250	7,48	17,5	100	5,29	14,5	50
	680	4,5	13,0	22,3	250	8,25	18,3	100	5,83	15,3	50
	820	5,2	14,3	23,1	250	9,06	19,1	100	6,40	16,1	50
	1,0 k	6,0	15,8	24,0	250	10,0	20,0	100	7,07	17,0	50
	1,2 k	6,8	17,3	24,8	250	11,0	20,8	100	7,75	17,8	50
	1,5 k	8,0	19,4	25,7	250	12,2	21,8	100	8,66	18,8	50
	1,8 k	8,9	21,2	26,5	250	13,4	22,6	100	9,49	19,5	50
	2,2 k	10,1	23,5	27,4	250	14,8	23,4	100	10,5	20,4	50
	2,7 k	11,4	26,0	28,3	250	16,4	24,3	100	11,6	21,3	50
10 k	3,3 k	2,5	28,7	29,2	250	18,2	25,2	100	12,8	22,2	50
	3,9 k	2,9	31,2	29,9	250	19,7	25,9	100	14,0	22,9	50
	4,7 k	3,3	34,3	30,7	250	21,7	26,7	100	15,3	23,7	50
	5,6 k	3,9	37,4	31,5	250	23,7	27,5	100	16,7	24,5	50
	6,8 k	4,5	41,2	32,3	250	26,1	28,3	100	18,4	25,3	50
	8,2 k	5,2	45,3	33,1	250	28,6	29,1	100	20,2	26,1	50

Annex X (informative)

Cross reference

The revision of this standard has resulted in a new clause numbering. The following table provides a cross reference between the clause numbering of this revision compared to the prior revision of this standard.

IEC/TR 60440:1973 1 st edition Clause	IEC 60440:201X 1 st edition Clause	Notes
1	1	Scope and object are merged into one
2		
—	2	New clause
—	3	New clause
3	4.1	—
4.0		
4.1	4.2	—
4.2		
4.3	4.1	—
4.4		
4.5	4.3	Divided in to subclauses
4.6	5.1	—
4.7	4.3.7	—
5	5	Divided into subclauses
—	6	New clause

BIBLIOGRAPHY

Danbridge A/S, *“Reliability Testing of Nominally Linear Components by Measuring Third Harmonic Distortion”*, Application Note, 2002

IEC 60027 (all parts), *Letter symbols to be used in electrical technology*

ISO 60617, *Graphical symbols for diagrams*

ISO 1000, *SI Units and recommendations for the use of their multiples and of certain other units*

Kühl, R.W. and Ewell, G.J., *“Third Harmonic Testing: Current Resistor Applications”*, Proceedings, 15th European Passive Components Symposium CARTS-EUROPE 2001, Copenhagen, Denmark, 2001, pp. 85 - 93.

Kuehl, R.W., *“Reliability of thin-film resistors: Impact of third harmonic screening”*, Microelectronics Reliability 42 (2002), pp. 807 - 813.
