



Figure 16: Noise Level inside the closed Noise Test Chamber, without noisy transformer. This measurement shows the ambient “reverberant” distance independent noise level inside the noise test chamber. The maximum noise level is just above NC-0 (threshold of hearing) at 50/60 Hz and 600 Hz, indicating the validity of measurements at or above this threshold.